

## Model HM093HFX UB60 / HN1639HC NK0

Model name	HM093HFX UB60 / HN1639HC NK0
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.84 kW	2.81 kW
COP	4.90	3.20

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	49 dB(A)	49 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	206 %	147 %
Prated	9.00 kW	9.00 kW
SCOP	5.23	3.75
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.00 kW	8.00 kW
COP Tj = -7°C	3.48	2.50
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.90 kW	4.90 kW
COP Tj = +2°C	5.04	3.72
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.10 kW	3.10 kW

COP Tj = +7°C	6.75	4.85
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.60 kW	3.60 kW
COP Tj = 12°C	8.80	5.00
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.00 kW	9.00 kW
COP Tj = Tbiv	3.20	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	9.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.20	2.28
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	75 °C	75 °C
Poff	10 W	10 W
PTO	30 W	30 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3554 kWh	4965 kWh